



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
104 North First Street
Amite, LA 70422
985-748-2011
<http://www.dhh.la.gov/lab>



February 22, 2024

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Public Water System:	LA1103195	Sample ID:	A2400994-001
	VILLAGES OF BOCAGE- MADISONVILLE	Sample type:	Routine
PWS facility:	DS0950	Sample collector:	Shannon Johnson
	DISTRIBUTION SYSTEM	Collection date:	2/21/2024 10:30:00AM
Sampling location:	TCR-005	Lab submittal date:	2/21/2024 3:40:00PM
	69017 TAVERNY COURT		
Collection address:			
Free chlorine (mg/L):			
Total chlorine (mg/L):	1.27		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Reviewed by: Eric Tran